



## Pool Checklist

Use this to verify that the pool is in compliance daily.

### Water Quality Standards

- Test kits (a DPD Drop Test Kit is preferred)
- pH between 7.2-7.8
- Free chlorine residual of at least 1 ppm in pools/spas and 2 ppm in wading pools
- Free bromine residual of at least 2 ppm in pools, wading, and spas.
- CPO inspects pool daily and maintain written records
- Written records in good condition
- Fecal and vomitus clean up guidance on site

### Safety

- Main drain visible at all times from pool deck
- Main drain covers comply with VGB, in good condition, and securely attached
- Equalizer line covers meet VGB act requirements. Equalizer line are not required and may be plugged for flooded suction outlet configurations only (pump is below main drain).
- Automatic feeder pumps prevented from operating while the circulation pump is not in operation
- 12 ft safety pole with body hook available
- ¼ inch throwing rope available
- "Warning-No Life Guard On Duty" signage posted if required
- A permanently affixed telephone visible or phone or call box that directly dials 911 or that is monitored 24hr/365 days by an emergency notification system
- A sign with legible letters posted at the phone providing dialing instructions, address of the pool location, and the phone number

### Maintenance

- Depth markers on deck and walls of pool in good condition
- "No Diving" markers on the deck adjacent to all areas of the pool less than five feet deep in good condition
- Leading edge of stairs or underwater seats contrasting band in good condition
- Underground lights covered and underwater lights secure
- Hand rail and ladders tightened and escutcheon plates in place
- End caps on open ends of ladders
- Self-closing and self-latching gate and doors that open away from the pool deck (check windows for alarms or barriers in place)
- Skimmers and baskets operating in good repair and clean
- Deck free of hazards or offsets greater than one-half inch
- Over the rim fill spouts are shielded and do not present a hazard
- "Shower before swimming" sign posted
- Pool rules signage posted
- "Pool closed" signs available